◆ **TO BE PRINTED ON 24" X 36" PLAN SHEETS PER ORIGINAL FORMAT.** ◆

## Site Vicinity Map

Not To Scale




Site Vicinity Map
Not To Scale

PROJECT DATA:

| | | | |
|---|---|---|---|
| **Occupancy Group(s):?** | **U** | **Sprinkled:** | **No** |
| **Type(s) of Construction:** | **VB** | **Risk Category:** | **II** |
| **Stories/Height:** | **One** | **Seismic Design** | **Category:D** |
| **Building Area:** | **280 sq. ft.** | **Valuation:** | **$53,840** |
| **Occupant Load** | **:n/a** | | |

Scope Of Work

The Construction Of A New Handicap Rest Room

2019 California Building Code
2019 California Residential Code
2019 California Mechanical Code
2019 California Plumbing Code
2019 California Electrical Code
2019 California Green Building Standards
Are Applicable To This Project

COLOR REQUIRED.

**REVIEWED**
*FOR*
CODE COMPLIANCE
***Nov 05, 2021***
INTERWEST CONSULTING GROUP

Drawing Index


DESIGN CRITERIA

Floor Live Load = 40 psf
Roof Live Load = 30.3 psf

Roof Snow Load:
Ground snow load, Pg = 70 psf
Flat-roof snow load, Pf - use psf
Snow exposure factor, Ce = 0.9 (other )
Thermal factor, Ct 1.1 (Other )

Wind Design speed:
Basic wind speed (3-sec gust) = 95 mph
Other ( ) mph
Wind importance factor, *I* = 1.0
Wind exposure = C
Earthquake design data:
Seismic importance factor, *I*= 1.0
Mapped spectral response accelerations:
Ss = 0.6697
S1 = 0.2457
Site Class D
Spectral response coeff.:
SDS = 0.6
SD1 = 0.3
Governing Seismic Design Category, SDC = D

**WILDLAND URBAN INTERFACE**
**All exterior materials shall comply with CRC R337 & CBC 7-A**
**Defensible space requirement shall be enforced**

**REQUIRED INSPECTION CHECKLIST SHALL BE COMPLETED, SIGNED AND GIVEN TO THE INSPECTOR AT THE BEGINNING OF EACH INSPECTION.**




Legend

| | |
|---|---|
| (N) U E | (N) Underground Elect #12 240v 2 circuits to (E) Sub Panel In Pump House |
| (N) L/P | 125 Gallon Vertical Propane Tank DOT 3 4' Sq Conc Pad |
| (E) R | (E) Restroom |
| F C P | Flat Concrete Pad |
| Slope | → |
| New Instantaneous Water Heater | (N) INST W/H |




Scale: 1 = 30
A.P.N. 062-082-022-000




Enlarged Area Not To Scale

**REVIEWED FOR CODE COMPLIANCE**
USING THE FOLLOWING CODES:
- ☐ 2019 CALIFORNIA RESIDENTIAL CODE
- ☑ 2019 CALIFORNIA BUILDING CODE
- ☑ 2019 CALIFORNIA ELECTRICAL CODE
- ☑ 2019 CALIFORNIA PLUMBING CODE
- ☑ 2019 CALIFORNIA MECHANICAL CODE
- ☑ 2019 CALIFORNIA ENERGY CODE
- ☑ 2019 CALIFORNIA GREEN BUILDING STANDARDS CODE
- ☐ 2019 CALIFORNIA BUILDING CODE - STRUCTURAL DESIGN PROVISIONS ONLY
- ☐ 2019 CALIFORNIA FIRE CODE
- ☐ OTHER: _____

COMPLETION OF THIS REVIEW DOES NOT AUTHORIZE CONSTRUCTION TO PROCEED IN VIOLATION OF ANY FEDERAL, STATE OR LOCAL REGULATIONS.

BY: *DeniseReese* DATE: *Nov 05, 2021*

INTERWEST CONSULTING GROUP

PLACER COUNTY REVIEW ACCEPTED
per CONSULTANT REVIEW
Nov082021
Permit # ***21-03279***
Plans and specifications shall not be changed without REVIEW from the Building Services Division
***ELECTRONIC SUBMITTAL***


Custom Home Design & Drafting
1545 Grass Valley Hwy #40
Passive Solar Design,
Title 24 Documentation
(530) 823-1304
email: ebernard2978@sbcglobal.net


GEB

Dutch Flat Swimming Pool Restrooms
1045 Mattel Drive
Dutch Flat, CA
Placer County

Drawn By
*Ed Bernard*
Checked By
Date
October 20, 2021
Scale
*As Noted*
Job Number
*2021-10-1*
1 *2021-11-1*
Sheet 1 of 6 Sheet

***21-03279***




## Underground Plumbing Plan

Not To Scale

Inst W/H
Gas Inlet ¾" Blk Iron Piping

Cold Water Inlet ¾" PVC SCH 40 Pipe
Potable Water Piping ¾" Copper Pipe,
With ¼" outlet

Exterior windows, skylights and glazed doors shall be insulating-glass units with a minimum of one tempered pane, or glass block units, or have a fire rating of 20 minutes. CBC 708A

Exterior doors shall be solid core with stiles and rails not less than 1 3/8 inches thick with interior field panel thickness no less than 1 ¼ inch or shall have a fire rating of 20 minutes. CBC 708A

*Shear Wall Schedule (Stud Framed)*

| Mk | Sheathing | Sheathing Edge Nailing | 3/8" Dia. Typ. Anchor Bolting Sill Plate | Roof/Top Plate Shear Transfer | Shear Txfr Bottom Plt to Rim Jst | Sill Plate Rim/Blkg | Capacity lb/ft | |
|---|---|---|---|---|---|---|---|---|
| A | 3/8" SPS 1 side | 8d @ 6" one side | @ 36" OC 2x Sill Plate | H1 @ 24" OC | 16d @ 4" | 16d @ 4" | 307 220 | Wind Seismic |
| B | 3/8" SPS 1 side | 8d @ 4" one side | @ 25" OC 2x Sill Plate | H1 @ 24" OC | 16d @ 3" | 16d @ 3" | 447 320 | Wind Seismic |
| C | 3/8" SPS 1 side | 8d @ 3" one side | @ 19" OC 2x Sill Plate | H1 @ 24" OC & A35 @ 24" OC | 16d @ 3 | 16d @ 3" | 575 410 | Wind Seismic |
| D | 3/8" SPS 1 side | 8d @ 2" one side | @ 19" OC 3x Sill Plate | H1 @ 24" OC & A35 @ 24" OC | SDS25312 @ 5.5"oc | 16d @ 2" | 742 530 | Wind Seismic |
| E | 3/8" SPS 2x sides | 8d @ 3" ea side | @ 12" OC 3x Sill Plate | H1 @ 24" OC & A35 @ 12" OC | 16d @ 2" @ 3.5"oc | 16d @ 2" | 1150 820 | Wind Seismic |

Notes:
*1. Sheathing nailing is at panel edges. Panel field nailing for all wall types is 8d @ 12.*
*2. Values are for panel edges applied directly to framing. All edges must be supported or blocked per sheet S1.*
*3. Stagger joints where panel is applied to both faces of wall.*
4. 3X sill plate and all edge framing shall be used for shear walls D and E.
5. Maximum stud spacing is 24"oc.







## Typical Handicap Restroom

Scale: ¼" = 1'-0"




11B-605.2 Height and Depth
Urinals shall be the stall-type or the wall-hung type with the rim 17 inches (432 mm) maximum above the finish floor or ground. Urinals shall be 131/2 inches (343 mm) deep minimum measured from the outer face of the urinal rim to the back of the fixture.




## Floor Plan

Scale: ¼" = 1'
Building Area: 280 Sqft
Covered Entry: 100 "

COF Centerline Of Fixture
minimum & maximum of 17" to 18".
3068 ASC Automatic Self Closing Door

Door closers shall be adjusted so that from an open position of 90 degrees, the time required to move the door to a position of 12 degrees from the latch is 5-seconds. Reference 2019 CBC 11B-404.2.8.1.




## Left Elevation

Scale4: ¼" = 1' - 0"




Slope: 1" 12" 1 / 12 = 8.3%
Cross Slope: 0" 12"

11B-403.3 Slope
The running slope of walking surfaces shall not be steeper than 1:20.
The cross slope of walking surfaces shall not be steeper than 1:48.

405.3 Cross Slope. Cross slope of ramp runs shall not be steeper than 1:48.

Advisory 405.3 Cross Slope. Cross slope is the slope of the surface perpendicular to the direction of travel.
Cross slope is measured the same way as slope is measured (i.e., the rise over the run).

## Back Elevation

Scale4: ¼" = 1' - 0"







Accessible Wheel Chair Ramp

## Front Elevation

Scale4: ¼" = 1' - 0"

1 x 8 Hardy Board Siding

Latches and Closers
Door-opening hardware shall be centered between 34 and 44 inches above the floor.
Reference 2019 CBC 11B-404.2.7.

11B-703.7.2.6 Toilet and Bathing Facilities Geometric Symbols
Geometric symbols at entrances to toilet and bathing rooms shall be mounted at 58 inches (1473 mm) minimum and 60 inches (1524 mm) maximum above the finish floor or ground surface measured fro the centerline of the symbol. Where a door is provided the symbol shall be mounted within 1 inch (25 mm) of the vertical centerline of the door.




11B-703.6 Pictograms
Pictograms shall comply with Section 11B-703.6.
11B-703.6.1 Pictogram Field
Pictograms shall have a field height of 6 inches (152 mm) minimum. Characters and Braille shall not be located in the pictogram field.
FIGURE 11B-703.6.1

PICTOGRAM FIELD
11B-703.6.2 Finish and Contrast
Pictograms and their field shall have a non—glare finish. Pictograms shall contrast with their field with either a light pictogram on a dark field or a dark pictogram on a light field.
11B-703.6.3 Text Descriptors
Pictograms shall have text descriptors located directly below the pictogram field. Text descriptors shall comply with Sections 11B-703.2, 11B-703.3 and 11B-703.4.
11B-703.7 Symbols of Accessibility

## Right Elevation

Scale4: ¼" = 1' - 0"




1210.2.1 Floors and Wall Bases: In other than dwelling units, toilet, bathing and shower floor finishes material shall have a smooth, hard, nonabsorbent surface. The intersections of such floors with wall shall have a smooth, hard, nonabsorbent , vertical base that extends upward onto the walls not less than 4 inches (102 mm).

1210.2.2 Walls and Partitions: Walls and partitions within 2 feet (610 mm) of service sinks, urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of not less than 4 ft (1219 mm) above the floor, and except for structural elements, the material used in such walls shall be of a type that is not adversely affected by moisture.

Exception: This section does not apply to the following building spaces:
1: Dwelling units and sleeping units.
2: Toilet rooms that are not accessible to the public and which have not more than one water closet.

Accessories such as grab bars, towel bars, paper dispensers and soap dishes, provided on or within walls, shall be installed and sealed to protect elements from moisture.

11B 608.5 Controls. Controls, faucets and shower spray units shall comply with Section 11B 309.4. Controls and faucets shall be of a single-lever design.

11B 603.3 Height. Lavatories and sinks shall be installed with the front of the higher of the rim or counter surfaces 34 inches Z(864 mm) above the finished floor.

11B 606.4 Faucets. Controls for faucets shall comply with Section 11B-309. Hand-operated metering faucets shall remain open for 10 seconds minimum.

11B 606.5 Exposed Pipes and Surfaces. Water supply and drain pipes under lavatories and sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under lavatories and sinks.

11B 606.6 Adjacent Side Wall or Partition. Lavatories when located adjacent side wall or partition shall be minimum of 18 inches (457 mm) to the center of the fixture

11B 607.7 Where forward approach is required at a sink, knee and toe clearance shall be provided in compliance with Section 11B 306

***11B*-505.7 Cross Section.** Handrail gripping surfaces shall have a cross section complying with *11B*-505.7.1 or *11B*-505.7.2.

***11B*-505.7.1 Circular Cross Section.** Handrail gripping surfaces with a circular cross section shall have an outside diameter of 1¼ inches (31.8 mm) minimum and 2 inches (51 mm) maximum.

***11B*-505.7.2 Non-Circular Cross Sections.** Handrail gripping surfaces with a non-circular cross section shall have a perimeter dimension of 4 inches (102 mm) minimum and 6¼ inches (159 mm) maximum, and a cross-section dimension of 2¼ inches (57 mm) maximum.




Figure 11B - 505.7.2
Handrail Non-Cicular Cross Section

***11B*-505.10 Handrail Extensions.** Handrail gripping surfaces shall extend beyond and in the same direction of stair flights and ramp runs in accordance with *11B*-505.10.

**EXCEPTIONS: 1.** Extensions shall not be required for continuous handrails at the inside turn of switchback or dogleg stairs and ramps.
**2.** In assembly areas, extensions shall not be required for ramp handrails in aisles serving seating where the handrails are discontinuous to provide access to seating and to permit crossovers within aisles.
**3.** In alterations, full extensions of handrails shall not be required where such extensions would be hazardous due to plan configuration.

***11B*-505.10.1 Top and Bottom Extension at Ramps.** Ramp handrails shall extend horizontally above the landing for 12 inches (305 mm) minimum beyond the top and bottom of ramp runs. Extensions shall return to a wall, guard, or the landing surface, or shall be continuous to the handrail of an adjacent ramp run.




*11B-609.4 Grab Bars*
Grab bars shall be installed in a horizontal position, 33 inches (838 mm) minimum and 36" (914 mm) maximum above the finished floor measured to the top of the gripping surface.

*11B - 604.7 Dispensers*
Toilet paper dispensers shall comply with section *11B - 309.4* and shall be 7 inches (178 mm) minimum and 9 inches ( mm) maximum in front of the water closet measured to the center of the dispenser.
The outlet of the dispenser shall be *( below the grab bar 19 inches ( 483 mm) minimum above the finish floor)* and shall not be located behind the grab bars.
Dispenser shall not be of a type that controls delivery or that does not allow continuous paper flow

***11B-703.4.2* Location.** Where a tactile sign is provided at a door, the sigh shall be located alongside the door at the latch side.
Where a tactile sign is to be provided at double doors with one active leaf, the sign shall be located on the inactive leaf.
Where a tactile sign is to be provided at double doors with two active leafs, the sign shall be located to the right side of the right hand door.
Where there is no wall space at the latch side of a single door or at the right side of double doors, signs shall be located on the nearest adjacent wall.
Signs containing tactile characters shall be located so that a clear floor space of 18 inches (457mm) minimum by 18 inches (457mm) minimum, centered on the tactile characters is provided beyond the arc of any door swing between the closed position and 45 degree open position.
*Where provided, signs identifying permanent rooms and spaces shall be located at the entrance to, and outside of the room or space .*
*Where provided, signs identifying exist shall be located at the exit door when approached in the direction of egress travel.*
***Exception:** In alterations where sign installation locations identified in Section 11B-703.4.2 are obstructed or otherwise unavailable for sign installation, signs with tactile characters shall be permitted on the push side of doors with closers and without hold-open devices.*







11B 703.7.2.1 International Symbol Of Accessibility.
The International Symbol Of Accessibility shall comply with figure 11B-703.7.2.1. The symbol shall consist of a white figure on a blue background. The color blue shall approximate FS 15090 in Federal Standard 595C.
Exceptions:
1. The appropriate enforcement agency may approve other colors provided the Symbol contrast is light on dark or dark on light.
2. On the Accessibility function button on hall call consoles in a destination-oriented elevators system the International Symbol Of Accessibility shall be a white symbol on a black background.

**REVIEWED**
*FOR*
CODE COMPLIANCE
***Nov 05, 2021***
INTERWEST CONSULTING GROUP

11B 603.3 Height. Lavatories and sinks shall be installed with the front of the higher of the rim or counter surfaces 34 inches Z(864 mm) above the finished floor.
11B 606.4 Faucets. Controls for faucets shall comply with Section 11B-309. Hand-operated metering faucets shall remain open for 10 seconds minimum.

11B 606.5 Exposed Pipes and Surfaces. Water supply and drain pipes under lavatories and sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under lavatories and sinks.

11B 606.6 Adjacent Side Wall or Partition.
Lavatories when located adjacent side wall or partition shall be minimum of 18 inches (457 mm) to the center of the fixture

11B 607.7 Where forward approach is required at a sink, knee and toe clearance shall be provided in compliance with Section 11B 306


G E B
Custom Home Design & Drafting
Passive Solar Design,
Title 24 Documentation
(530) 823-1304
email: cbernard2978@sbcglobal.net


REGISTERED PROFESSIONAL ENGINEER ROGER L. BLAIR C 048824 CIVIL STATE OF CALIFORNIA
11/1/21

# A New Accessible Restroom For Dutch Flat Community Swimming Pool

1045 Matel
Dutch Flat, CA 95714

| | |
|---|---|
| Drawn By | *Ed Bernard* |
| Checked By | *Mike Mutto* |
| Date | October 20, 2021 |
| Scale | *As Noted* |
| Job Number | *2021-10-1* |
| ⚠1 | November 1, 2021 |
| Sheet | 2 Sheet of 6 Sheet |

21-03279




## Foundation Cross Section B - B'
Scale: $\frac{1}{4}$" = 1' - 0"




## Foundation PLan
Scale: $\frac{1}{4}$" = 1' - 0"




## Details
Scale: 1' = 1' - 0"




## Soffit Detail For WUI
Scale: $\frac{1}{2}$" = 1' - 0"




## Roof Framing Plan
Scale: $\frac{1}{4}$" = 1' - 0"

EV — Eave Vent

2 x 6 Framed Walls

Beam #1 6 x 6 x 3'-3" DF #2

## Left Wall Framing
Scale: $\frac{1}{4}$" = 1' - 0"




## Back Wall Framing
Scale: $\frac{1}{4}$" = 1' - 0"




## Cross Section B - B'
Scale: $\frac{1}{4}$" = 1' - 0"




## Front Wall Framing
Scale: $\frac{1}{4}$" = 1' - 0"




## Covered Entry Way Framing
Scale: $\frac{1}{4}$" = 1' - 0"




## Right Wall Framing
Scale: $\frac{1}{4}$" = 1' - 0"

REGISTERED PROFESSIONAL ENGINEER ROGER L. BLAIR 11/1/21 C 048824 CIVIL STATE OF CALIFORNIA

REVIEWED
FOR
CODE COMPLIANCE
Nov 05, 2021
INTERWEST CONSULTING GROUP


Custom Home Design & Drafting
Passive Solar Design,
Title 24 Documentation
(530) 823-1304
email: ebernard2978@sbcglobal.net


GEB

A New Accessible Restroom For Dutch Flat Community Swimming Pool
1045 Matel
Dutch Flat, CA 95714

| | |
|---|---|
| Drawn By | *Ed Bernard* |
| Checked By | *Mike Mutto* |
| Date | October 20, 2021 |
| Scale | *As Noted* |
| Job Number | *2021-10-1* |
| 1 | November 1, 2021 |
| Sheet | 3 of 6 Sheet |

21-03279




| Header Schedule | | |
|---|---|---|
| width of opening | header depth "d" | |
| | brng wall | non-brng |
| 0' to 4'-0" | 6" | 4" |
| 4'-1" to 8'-0" | 8" | 6" |
| 8'-1" to 10'-0" | 10" | 8" |
| typ unless noted otherwise | | |

## 1 Typical Stud Wall Framing




Beam Perpendicular to Wall

Beam Parallel to Wall

## 2 Post & Beam Connections




Notes:
1. Predrill corners of notches so as not over cut.
2. Notches on ends of joists & headers shall not exceed 1/4 the joist depth.
3. Notches in the top of joists shall not exceed 1/4 the depth and shall not be located in the middle third of the span.
4. Notches on the bottom of joist allowed only where specifically shown on drawings.
5. Holes bored in joists shall not be within 2 inches of the top or bottom and shall not have a diameter larger than the 1/4 depth of the joist.

## 3 Notches & Holes in Joists & Headers




## 4 Typical Stud Framing at Corners

## Wood

1. All structural wood shall conform with the following specification: Douglas Fir — Coast Region — WCLIB grading rules #17 DF #1, except 2x4 and 2x6 wall studs, plates, and blocking may be DF #2. Redwood — California Redwood Association Grading Rules, latest edition. Glued Laminated Beams — Standard Spec. for Structural Glued Laminated Timber AITC 117 latest edition. Submit shop drawings prior to fabrication of glued-laminated members. Plywood — U.S. Product Standard P.S. 2–92 for soft plywood Struct 1 @ walls; CDX @ floors and roof — U.N.O. Pressure Treated Douglas Fir — 2019 CBC Standard No. 2303–3.
2. All wood in direct contact with earth or concrete shall be pressure treated.
3. Bearing and shear walls shall have double top plates, lapped at wall and partition intersection with 2–16d nails. Splice upper and lower plates as in Detail 1 on Typical Detail sheet.
4. Provide solid blocking, or rim board between joists and rafters at all supports.
5. Provide blocking at all ceiling levels.
6. Joists under and parallel to partitions shall be doubled and nailed together.
7. Holes for bolts in wood shall be bored with a bit of the same nominal diameter as the bolt plus 1/16".
8. Holes for lag screw shall be first bored to the same diameter and depth as the shank and the rest no larger than the root of the thread.
9. Lag screws and wood screws shall be screwed and not driven into place. Soap may be used to lubricate the screws.
10. All bolts and lag screws shall be provided with metal washers under heads and nuts which bear on wood. Applies also to inserted expanding fasteners, Red Head, etc.

| Bolt Diameter | MI Washer | Steel Washer |
|---|---|---|
| 1/2" | 2" dia x 1/4" | 2"x2"x 3/16" |
| 5/8" | 3" dia x 1/4" | 3"x3"x 1/4" |
| 3/4" | 3 1/2" dia x 5/16" | 3 1/2"x3 1/2"x 1/4" |
| 1" | 4" dia x 5/16" | 3 1/2"x3 1/2"x 1/4" |

11. All bolts and lag screws shall be tightened on installation and retightened before closing in or at completion of job.
12. Lay all structural plywood on roof and floors with face grain perpendicular to support unless noted otherwise.
13. Block SP joints with 2x4 flat blocking where noted on roof or floor framing plans and with blocking same as studs at walls. Use plyclips at midspan of unsupported plywood edges.
14. Connector hardware model number are those for Simpson Strong-Tie Company. Equivalent connectors with ICC acceptance may be substituted. All joist hangers shall be Simpson U series unless noted otherwise.
15. Notify Structural Engineer after wall, floor, and roof SP nailing has been completed and a minimum of 48 hours prior to concealing SP.
16. Cutting and notching of exterior walls and bearing partitions shall not exceed 25 percent of the stud width.
17. Cutting and notching of non–bearing partitions supporting no loads other than the weight of the partition shall not exceed 40 percent of the stud width.
18. A bored hole not greater than 40 percent of the stud width may be bored in any wood stud.
19. Bored holes not greater than 60 percent of the width of the stud are permitted in non–bearing partitions and in any wall where each bored stud is doubled, provided not more then two successive double studs are so bored.
20. Wood exposed to weather shall be approved wood of natural resistance to decay or treated wood.




## 5 Typical Opening in Roof or Wall Plywood Diaphram

(apngs to be 4'–0" maximum)




## 6 Typ Non–Brg Truss to Wall

Typ. @ all Interior Walls




## 7 Typ Wood Clearances

## Foundations

1. All foundation work shall be done in accordance with the requirements of the 2019 CBC.
2. Bottoms of all foundations shall be level. Changes in bottom of foundation elevation shall be made according to stepped footing Detail 11.
3. All pile caps, grade beams, tie beams & other footings shall be formed unless specifically approved by the Structural Designer.
4. Vapor barriers under slabs shall conform with ASTM E–1745. 10 Mil for residential slabs. 15 Mil for commercial slabs or residential slabs where heavy placing equipment is used.
5. Control joints in slab shall be placed at 24' min in each direction & at re–entrant corners.
6. Engineered fill is preferred to be AB–3/4 (self–compacting) per ASTM C 136 or D 422. Local fill is to be homogenous mixture of soil and rock free of vegetation, organic material, rubbish and/or rubble. Material shall be compacted per ASTM D–1557 in 8" lifts to 90% (up to 5' only), and 95% above 5'. Local fill to be verified by Engineer for expansive soil, and rock size issues.
7. Read Soils Report for various compaction requirements by location.







Single Layer Bars




Double Layer Bars

## 8 Typical Corner Reinforcing




| SIMPSON HDU | SIMPSON ANCHOR | EMBEDMENT $d_e$ | FOOTING WIDTH | SIDE MEMBER | CAPACITY (lbs.) |
|---|---|---|---|---|---|
| HDU2 | PAB5 | 4" | 12" | 4x4 | 3075 |
| HDU4 | PAB5 | 6" | 18" | 4x4 | 4565 |
| HDU5 | PAB5 | 6" | 18" | 4x4 | 5645 |
| HDU8 | PAB7 | 9" | 27" | 4x6 | 7870 |

Notes:
1. SEE SIMPSON CATALOG FOR OTHER APPLICATIONS.
2. ANCHOR BOLT TO BE INSTALLED PER MFG. INSTRUCTIONS
3. MIN. 2500psi CONCRETE

Mis–Placed Anchor Bolts may be accomodated by adding CNW Coupler and All–Thread of equal size to Anchor Bolt. Hold–Down can then be placed up the stud a maximum of $\frac{1}{2}$ the end–stud height. All–thread may not exceed 10 Deg. from vertical. This does not remove AB & Washer to Sill plate, or AB edge distance requirements of the CBC. This is only allowed for Hold–Downs whose load is less than 5,000lb. per Engr calculations.

## 9 Hold Down Detail




## 10 Post and Beam Detail

Note: Use where post is not within wall UON

## 11 Footing Step

Ref. CBC 1809.3

## Concrete

1. Structural concrete shall attain 28 day compressive strength f'c = 2500psi
2. Concrete mix design shall be prepared by an independent qualified laboratory Selection of concrete mix proportions shall be per 2019 CBC section 1905.2. Fly ash shall be used as a direct replacement of cement by 20% Fly ash shall have a mercury content better than 11 ppb, nor be from plants burning, hazardous, municipal solid or Medical waste. (consistent with DHPS Guidlines.)
3. Cement shall conform to ASTM C–150–07 type I or II.
4. Concrete aggregates shall conform to ASTM C–33–07. Aggregates for lightweight concrete shall conform to ASTM C–330–05.
5. Reinforcing steel to be welded shall conform to ASTM A706.
6. Reinforcing steel shall conform to ASTM A615 Grade 40 for #3 and #4 bars and Grade 60 for #5 and Larger, or Grade 60 for Seismic D & E Zones. Wire fabric shall conform to ASTM A–82.
7. Dimensions shown for location of reinforcing are to the face of main bars and denote clear coverage. Concrete coverage shall be as follows: concrete deposited against ground (except slabs) –3". Concrete exposed to earth or weather–1–1/2". Slabs (on ground) –1–1/2".
8. Splices in continuous reinforcement shall be 48 bar diameters and splices in adjacent bars shall be not less than 5'–0" apart. Splice continuous bars in spandrels, grade beams, etc., as follows: Top bars at mid–span; Bottom bars at centerline at support, unless noted otherwise. Splices in wwf shall be 1 1/2 meshes wide.
9. Construction joints shall be made rough and all laitance removed from the surface. Concrete may be roughened by chipping the entire surface, sand blasting or raking the surface to produce 1/4" deep deformations.
10. Remove all debris from forms before casting any concrete.
11. Reinforcing, dowels, bolts, sleeves, etc., to be embedded in concrete shall be tied securely in position before placing concrete.
12. Provide 2–#4x4'–0" diagonal reinforcing at mid–depth of slab at all reentrant corners typical.
13. Vapor barrier is to be placed under interior slabs and above the clean/crushed rock (class 2 aggregate) and is to conform with the requirements of ASTM E 1745 Class A, with a water vapor transmission rate less than or equal to 0.01 perms (such as 15–mil thick "Stego Wrap Class A") should be used. The vapor barrier should be placed directly below the concrete slab. Sand above the vapor barrier is not permitted. The vapor barrier should be installed in accordance with ASTM E1643. All seams and penetrations of the vapor barrier should be sealed in accordance with manufacturer's recommendations.

## Abbreviations

AB ..... anchor bolt
btwn ..... between
cc ..... center to center
CB ..... counter bore depth
CJ ..... ceiling joist
CLR ..... clear
CONC ..... concrete
CONT ..... continuous
CP ..... complete penetration
CSK ..... countersink
CTJ ..... control joint
DF ..... Douglas Fir
DL ..... dead load
(e) ..... existing
EJ ..... expansion joint
EN ..... edge nailing
FB ..... face of block
FC ..... face of concrete
FF ..... finish floor
FLR ..... floor
FS ..... face of stud
FTG ..... footing
GA ..... gauge
GLB ..... glued–laminated beam
HDR ..... header
HSB ..... high strength bolt (A–325)
HT ..... height
JH ..... joist hanger (Simpson)
JST ..... joist
LL ..... live load
LS ..... lag screw
LVL ..... laminated veneer lumber
LW ..... light weight
MI ..... malleable iron
MFR ..... manufacturer
(n) ..... new
NTS ..... not to scale
PAF ..... power acutated fastener (PDPAW 250 @ 24"cc U.N.O.)
PTDF ..... pressure treated douglas fir
RW ..... redwood
WS ..... wood screw
SPS ..... structural plywood sheathing
stfnr ..... stiffener
stggrd ..... staggered
T&B ..... top & bottom
T&G ..... tongue & groove
TN ..... toe nail
tof ..... top of framing
uno ..... unless noted otherwise
w/ ..... with
w/o ..... without
WWF ..... welded wire fabric
℄ ..... centerline
PL ..... plate
# ..... number or pounds
SQ ..... square
ø ..... round or diameter
..... continuous wood in section
..... wood blocking in section
..... end of wood piece

## Nailing Schedule

All nails for structural work shall be comman wire nails conforming to the following minimum sizes:

| | |
|---|---|
| 8d | 0.131"dia.x2–1/2" |
| 10d | 0.148"dia.x3" |
| 10d shorts | 0.148"dia.x1–5/8" plus thickness of S.P. |
| 16d | 0.162"dia.x3–1/2" (U.O.N) |
| 20d | 0.192"dia.x4" |

Holes shall be sub–drilled where necessary to prevent splitting. Nailing not noted below or on plans shall be a minimum of two nails at each contact. 8d nails for 1" material and 16d nails for 2" material.

1. Joists to sill or girder, toenail ---------- 3–8d
2. Bridging to joists, toenail each end ---------- 2–8d
3. 1"x6" subfloor or less to each joist, face nail ---------- 2–8d
4. Wider than 1"x6" subfloor to each joist, face nail ---------- 3–8d
5. 2" subfloor to joist or girder, blind & face nail ---------- 2–16d
6. Sole plate to joist or blocking, typical face nail ---------- 16d (3.5"x0.135") @ 16"o.c.
   Sole plate to joist or blocking, at braced wall panel ---------- 3–16d (3.5"x0.135") per 16" o.c.
7. Top plate to stud, end nail ---------- 2–16d
8. Stud to sole plate ---------- 4–8d,toenail or 2–16d, end nail
9. Double studs, face nail ---------- 16d (3.5"x0.135") @ 24"o.c.
10. Double top plates, typical face nail ---------- 16d (3.5"x0.135") @ 16"o.c.
    Double top plates, top splice, u.n.o ---------- 8–16d
11. Blocking between joists or rafters to top plate, toenail ---------- 3–8d
12. Rim joist to top plate, toenail ---------- 8d @ 6"o.c.
13. Top plates, laps and intersection, face nail ---------- 2–16d
14. Continuous header, two pieces, toenail ---------- 16d @ 16"o.c. along edge
15. Ceiling joists to plate, toenail ---------- 3–8d
16. Continuous header to stud, toenail ---------- 4–8d
17. Ceiling joists, laps over partitions, face nail ---------- 3–16d
18. Ceiling joists to parallel rafters, face nail ---------- 6–16d
19. Rafter to plate, toenail ---------- 3–8d
20. 1" brace to each stud & plate, face nail ---------- 2–8d
21. 1"x8" sheathing or less to each bearing ---------- 2–8d
22. Wider than 1"x8" sheathing to each bearing, face nail ---------- 3–8d
23. Built up corner studs ---------- 16d @ 24"o.c.
24. Built up girder & beams --- 20d @ 32"o.c. face nail at top & bottom staggered on opposite sides or 2–20d face nail at ends & at each splice
25. 2" planks ---------- 16d at each bearing
26. Collar Tie to Rafter, face nail ---------- 3 – 10d
27. Jack Rafter to Hip ---------- 3–10d toe nail or 2 16d face nail
28. Roof Rafter to 2x ridge beam ---------- 2–16d toe nail or 2 16d face nail
29. Joist to Band Joist, face nail ---------- 3–16d
30. Ledger Strip, face nail ---------- 3–16d
31. Wood structural panels:
    Subfloor, roof & wall sheathing to framing
    1/2" and less ---------- 6d
    19/32" – 3/4" ---------- 8d
    7/8" – 1" ---------- 8d
    1–1/8" – 1–1/4" ---------- 10d
    Combination subfloor underlayment to framing
    3/4" – 1" ---------- 8d
    1–1/8" – 1–1/4" ---------- 10d
    Nails spaced @ 6"o.c at edges, 12"o.c. @ intermediate supports except @ at all supports where spans are 48" or more. For nailing of braced wall panels or shear walls, see plan.
32. Panel siding to framing
    1/2" or less ---------- 6d
    5/8" ---------- 8d

# TYPICAL DETAILS AND NOTES

SPECIFIC DETAILS AND NOTES ON OTHER SHEETS SHALL PREVAIL OVER TYPICAL DETAILS AND NOTES

21-03279

SIERRA STRUCTURAL DESIGN
16180 S. ROCKY RD
MEADOW VISTA, CA 95722
mulkins@wizwire.com
(530) 878–8903

REVIEWED
FOR
CODE COMPLIANCE
Nov 05, 2021
INTERWEST CONSULTING GROUP

| REV | DATE | NAME |
|---|---|---|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |

REGISTERED PROFESSIONAL ENGINEER ROGER L. BLAIR 10/20/21 C 048824 CIVIL STATE OF CALIFORNIA

DF Pool Bathroom
1045 Mattel Drive
Dutch Flat, Ca 95714
TYPICAL STRUCTURAL

JOB # 20-97
DATE 10-15-20
SCALE N.T.S.
BY SM
SHT # S-1




1 EXTERIOR BEARING




2 INTERIOR BEARING




3 PORCH FOOTING




4 PORTAL SHEARWAL




5 ROOF SECTION




6 ROOF SECTION




7 ROOF SECTION




AS DETERMINED BY CHORD OR COLLECTOR FORCE CALCULATION, (12)-16d COMMON OR BOX NAILS MINIMUM PER ITEM 10 CBC TABLE23-II-B-1

NOTES:
(1) THE STRAPPING IS REQUIRED ALONG WALL ZONE AS SHOWN ON PLAN.
(2) THE ABOVE DETAIL IS BASED ON A TOP PLATE DETAIL
(3) 8-16d SPLICE NAILING MAY BE USED WHERE BOTH DIAPHRAM, & DRAG CALCUATIONS AGREE.

8 TOP PLATE SPLICE DETAIL
NO SCALE

SIERRA STRUCTURAL DESIGN
16180 S. ROCKY RD
MEADOW VISTA, CA 95722
(530) 878-8903

REVIEWED
FOR
CODE COMPLIANCE
Nov 05, 2021
INTERWEST CONSULTING GROUP

| REV | DATE | NAME |
|---|---|---|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |

REGISTERED PROFESSIONAL ENGINEER ROGER L. BLAIR 10/20/21 C 048824 CIVIL STATE OF CALIFORNIA

DF Pool Bathroom
1045 Mattei Drive
Dutch Flat, Ca 95714

STRUCTURAL DETAILS

JOB # 20-97
DATE 10-15-20
SCALE N.T.S.
BY SM
SHT # S-2

21-03279

## SHEAR NOTES

1. SEE DETAILS 9/S-1 FOR TYPICAL HOLDOWN INSTALLATION INFORMATION.
2. SHEATH ALL EXTERIOR SHEAR WALLS W/ ⅜" OSB W/ 8D @ 6"OC EDGE AND 12"OC FIELD NAILING U.O.N.
3. SEE SHEAR WALL AND BRACED WALL SCHEDULES FOR ADDITIONAL REQUIREMENTS.
4. WHERE SHEATHING IS APPLIED TO BOTH FACES OF A SHEAR WALL, USE 3X MINIMUM MEMBERS AT ALL FRAMING MEMBERS RE-CEIVING EDGE NAILING FROM ABUTTING PANEL EDGES AND AT ALL SILL PLATES.
5. ALL HARDWARE SPECIFIED SHALL BE SIMPSON
6. STRONG-TIE AND SHALL BE INSTALLED PER MFR'S RECOMMENDATIONS.
7. SEE DETAIL 5/S1 FOR FRAMING OF ANY OPENING IN SHEAR WALL.

## SHEAR WALL SCHEDULE

| Mk | SHEATHING | END STUDS | EDGE NAILING | ANCHOR BOLTS SILL PLATE | ROOF SHEAR TRANSFER | BOTT. PLATE SHEAR TXFR | CAPACITY (wind) |
|---|---|---|---|---|---|---|---|
| (A) | 3/8" SHEATHING Struc. Ply. | 2X MIN | 8D @ 6"OC | 5/8" DIA@ 36"OC 2X SILL PLATE | H1 @ 24"OC | 16d @ 4"OC | 307 #/ft |

NOTES:

1. See plans for location and details for application.
2. Values are for panel edges applied directly to framing. All edges must be supported or blocked per sheet S1.
3. Maximum wall stud spacing is 24"oc.
4. Simpson THD62800 may be used in-lieu of 5/8" Anchor Bolts. Follow Manufacturers Instructions.
5. Where Type A is called-out, use A34 @ 36" OC for Rim to Sill txfr.
6. For nail or staple requirements see SDPWS Table 4.3a.

## HOLDOWN SCHEDULE

| ID | DESCRIPTION | MAX. CAP. |
|---|---|---|
| △27 | SIMPSON MST27 STRAP, 30-16d NAILS TIE TOP PLATES SPLICES, WHERE PRESENT, ALONG LINES A & B | 3700# |

### SOLAR ROOF LOADS:

THE EQUIPMENT (PV PANELS) ELIMINATES THE PROBABILITY OF PEOPLE WALKING ON THE ROOF WITHIN THE EQUIPMENT FOOTPRINT THEREBY EFFECTIVELY ELIMINATING THE LIVE LOAD IN THE AREA OF THE EQUIPMENT. SINCE THE DESIGN LIVE LOAD UNDER 2019 CBC FOR A ROOF IS 20 PSF AND THE EQUIPMENT WEIGHT OF APPROX. 3PSF IT IS MY PROFESSIONAL OPINION THAT THE EXISTING ROOF SYSTEM, DESIGNED FOR A MINIMUM OF 20 PSF LIVE LOAD CAN HANDLE THE ADDITIONAL DEAD LOAD OF APPROX 3 PSF. SOLAR MOUNTING DESIGN BY OTHERS. LOADS MUST BE DISTRIBUTED ACROSS MEMBERS.

## ROOF SHEATHING NOTE

1. 1/2" CDX PLYWOOD SHEETING OR 15/32" OSB SHEETING.
2. ALIGN SHEETING WITH LONG EDGE PERPENDICULAR TO TRUSS/RAFTER.
3. NAIL ALL SUPPORTED EDGES & DRAG TRUSSES WITH 8d COMMON @ 6" O.C., NAIL FIELD WITH 8d COMMON @ 12" O.C. (PLYWOOD CLIPS @ MID-SPAN ARE OPTIONAL)
4. 1/8" MIN. GAP BETWEEN PLYWOOD IS REQUIRED. SEE TABLE R503.2.1.1(1) OF 2019 CRC. SHEATHING PATTERN TO BE ALTERNATING AND OPPOSING TO SUPPORT MEMBERS U.N.O.
5. BEAM MEMBERS ARE CALLED-OUT AS MINIMUM SIZE & STRENGTH. CONTRACTOR MAY INCREASE BOTH AS DESIRED.

## ROOF FRAMING PLAN NOTES

1. SEE SHEAR PLAN OR FLOOR PLAN FOR SHEAR PANEL LOCATIONS.
2. SHEATH ALL EXTERIOR SHEAR WALLS W/ ⅜" OSB WITH 8D @ 6"OC EDGE AND 8D @ 12"OC FIELD NAILING MIN. SEE SHEAR WALL AND BRACED PANEL SCHEDULES FOR ADDITIONAL REQUIREMENTS.
3. ALL HEADERS SHALL BE PER TABLE AT 1/S1, UON.
4. ALL FRAMING SHALL BE INSTALLED IN COMPLIANCE w/ 2019 CBC PROVISIONS.
5. ALL HARDWARE SPECIFIED SHALL BE SIMPSON STRONG-TIE AND SHALL BE INSTALLED PER MFR'S RECOMMENDATIONS.
6. ALL BEAMS AND HEADERS SHALL BE SUPPORTED WITH FULL BEARING. USE DF-L NO. 2 SUPPORTS, UON.
7. ALL DOUBLE TOP PLATES OF BEARING WALLS SHALL BE #2 DF-L. FOR DESIGNATED SHEAR WALL LINES, LAP SPLICES SHALL BE 48" W/12-16D OR CSC16 X 42" STRAP, U.N.O.
8. BEAM MEMBERS ARE CALLED-OUT AS MINIMUM SIZE & STRENGTH. CONTRACTOR MAY INCREASE BOTH AS DESIRED.
9. TRUSSES SHALL NOT BE CUT, NOTCHED, SPLICED OR OTHERWISE ALTERED IN ANY WAY WITHOUT APPROVAL OF ENGINEER.

## Structural Steel

1. Fabrication, erection and materials shall conform with the AISC specification for the design, fabrication, and erection of structural steel for building and uniform building code, latest edition.
2. Structural steel rolled shaped and plates shall conform with ASTM A-36 or A562 GRD. 50 as noted.
3. Steel pipe shall conform to ASTM A-53, Types E of S, grade B.
4. Structural tubing shall conform to ASTM A-500, grade B.
5. Welding shall be done by the electric arc process in accordance with American Welding Society standards, using only certified welders. All groove welds shall have complete penetration unless noted otherwise. All All exposed welds shall be ground.
6. All structural steel shall be erected plumb and true to line. Temporay bracing shall be installed and shall be left in place until other means are provided to adequately brace the structure.
7. n/a
8. Bolted connections shall consist of unfinished bolts conforming to ASTM A-307 unless noted otherwise. Where high strength bolts are indicated, bolts conforming to ASTM A325-X shall be provided. Bolts shall be of sufficient length to exclude threads from bearing.
9. Holes for unfinished bolts shall be of the same nominal diameter of the bolt plus 1/16". Use standard AISC gage and pitch for bolts except as noted otherwise.
10. Holes for bolts shall be of the same nominal bolt diameter plus 3/16" unless noted otherwise.
11. All structural steel shall receive minimum of one shop coat of red primer paint. Do not paint areas to be field welded, to receive friction type high strength bolts, or to be embedded in concrete. Provide additional painting as noted in the specifications.

## FOUNDATION NOTES

1. ALL REINFORCEMENT SHALL BE GRADE 60 UON.
2. ALL REINFORCEMENT SHALL BE PLACED IN CONFORMANCE W/ ACI REQUIREMENTS.
3. PROVIDE 1-#4 REBAR AT TOP & BOTTOM OF ALL FOOTINGS, 2 BARS MINIMUM.
4. USE 2500 PSI CONCRETE, 5 SACK MIX, 1 1/2" MAX AGGREGATE SIZE.
5. PROVIDE 5/8" DIA ANCHOR BOLTS, 7" EMBEDDMENT @ 6'-0"OC MAXIMUM AT ALL PERIMETER WALLS W/3"x3"x0.229" PLATE WASHERS, UON. MIN 1 BOLT BET. 4" & 12" OF EA. END OF SILL PLATE.
6. FOOTINGS SHALL EXTEND A MINIMUM OF 12" INTO FIRM DRY UNDISTURBED SOIL.
7. ALL FRAMING LUMBER IN DIRECT CONTACT W/CONCRETE SHALL BE PRESSURE TREATED DF#2.
8. ALL HARDWARE SHALL BE SIMPSON STRONG-TIE AND SHALL BE IN PLACE PRIOR TO FOUNDATION INSPECTION. SEE TYP. STRUCTURAL NOTES, OR PLAN SPECIFIED DETAIL SHEET FOR HOLDOWN INSTALLATION DETAILS.
9. SEE SHEAR PLANS FOR SHEAR PANEL INFORMATION.
10. HOLD DOWN ANCHORS SHALL BE SECURED IN PLACE PRIOR TO FOUNDATION INSPECTION AND ALL BOLTS SHALL BE RETIGHTENED PRIOR TO FINAL COVERING OF WALLS.
11. FASTENERS FOR PRESERVATIVE-TREATED AND FIRE-RETARDENT-TREATED WOOD SHALL BE OF HOT DIPPED ZINC-COATED GALVANIZED STEED, STAINLESS STEEL, SILICON BRONZE OR COPPER (CBC 2340.9.5)

### CONTRACTOR:

FIELD VERIFY ALL DIMENSIONS AND CONFIRM THAT STRUCTURAL MEMBERS AND CONNECTORS ADHERE TO CALIFORNIA BUILDING CODE SPAN TABLES AND SELECTION/INSTALLATION SPECIFICATIONS. CONTACT DESIGNER/ENGINEER IF ANY DISCREPANCIES OCCUR

### SOIL BEARING CAPACITY = 1,500 PSF.
### ALL CONCRETE SLABS TO BE (u.n.o.):

- 4" THICK OF 2500PSI CONCRETE OVER,
- 6"x6", #10 MESH WELDED WIRE FABRIC OR #3 BAR @ 18"OC EA. WAY OVER,
- 10-15 MIL "STEGO WRAP" VAPOR BARRIER & CAPILLARY BREAK, SEE FOUNDATION NOTE #4, (joints lapped not less than 6") SEE CONCRETE NOTE #13
- 4" OF ¾" OR LARGER OF CALTRANS CLASS 2 AGGREGATE BASE (AB) COMPACTED TO 95% MIN.

### DESIGN CRITERIA

| | |
|---|---|
| OCCUPANCY CATEGORY | II |
| IMPORTANCE FACTOR | 1.0 |
| ROOF DEAD LOAD | 10psf |
| ROOF LIVE LOAD | 18psf |
| SNOW LOAD (Ps) | 33.3psf |
| FLOOR LIVE LOAD | 40psf |
| WALL DEAD LOAD | 10psf |
| LATTITUDE | 39.211 |
| LONGITURDE | -120.83 |
| SS | .6697 |
| S1 | .2487 |
| R | 6.5 |
| CS | .0917 |
| SITE CLASS | D |
| SEISMIC BASE SHEAR | 0.74K |
| SDC | D |
| BASIC WIND SPEED | 95mph |
| WIND CATEGORY | II |
| WIND EXPOSURE | C |


SIERRA STRUCTURAL DESIGN
16180 S. ROCKY RD
MEADOW VISTA, CA 95722
mulkins@wizwire.com
(530) 878-8903


REVIEWED
FOR
CODE COMPLIANCE
Nov 05, 2021
INTERWEST CONSULTING GROUP

| REV | DATE | NAME |
|---|---|---|
| △ | | |
| △ | | |
| △ | | |
| △ | | |
| △ | | |

REGISTERED PROFESSIONAL ENGINEER
ROGER L. BLAIR
10/20/21
C 048824
CIVIL
STATE OF CALIFORNIA

# DF Pool Bathroom

1045 Mattel Drive
Dutch Flat, Ca 95714

## GENERAL NOTES

| | |
|---|---|
| JOB # | 20-97 |
| DATE | 10-15-20 |
| SCALE | N.T.S. |
| BY | SM |
| SHT # | S-3 |

21-03279